

# TEST CERTIFICATE

ST-11-01-03-08

**Product:** Laminate floor coverings „**BREEZE LINE, CHARM LINE, COURAGE LINE, TIME LINE, VANITY LINE, VITALITY LINE**“  
Dimensions: 1285 mm x 192 mm x 9,5 mm (inclusive AkusTec)

**Customer:** ter Hürne GmbH & Co. KG  
Ramsdorfer Str. 5  
46354 Südlohn

**Order:** External control of laminate floor coverings  
Testing and assessment of selected properties according to EN 13329

**Test report:** 279268/1

**Test results:**

- The general requirements according to table 1 are fulfilled.
- The classification requirements of the following levels of use are fulfilled:

|   |                        |
|---|------------------------|
| Resistance against abrasion:                    | class 21 - 23, 31 - 32 |
| Resistance against impact:                      | class 21 - 23, 31 - 32 |
| Thickness swelling:                             | class 21 - 23, 31 - 33 |
| Resistance to staining:                         | class 21 - 23, 31 - 33 |
| Resistance against soft chair rolls:            | class 21 - 23, 31 - 33 |
| Resistance against movement of a furniture leg: | class 21 - 23, 31 - 33 |


The products „**BREEZE LINE, CHARM LINE, COURAGE LINE, TIME LINE, VANITY LINE and VITALITY LINE**“ fulfil the general requirements according to table 1 and the classification requirements for the level of use 21 - 23 and 31 - 32 according to EN 13329 for the selected properties.

Extent of validity of the test certificate until 04.01.2012.

Dresden, 10.01.2011



Head of laboratory



Engineer in charge